

Radon Testing Results - Harbor Lights Middle School

Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Harbor Lights Middle School	Main Building	2nd Floor Library	4533383	3/28/2018	Detector Kit	1.5
Harbor Lights Middle School	Main Building	2nd Floor Library 8th	4607968	3/28/2018	Detector Kit	1.5
Harbor Lights Middle School	Main Building	2nd Floor Office	4533382	3/28/2018	Detector Kit	0.2
Harbor Lights Middle School	Main Building	2nd Floor Office	4525830	3/28/2018	Detector Kit	0.5
Harbor Lights Middle School	East Wing	2nd Floor Gym Class 8	4525935	3/28/2018	Detector Kit	0.7
Harbor Lights Middle School	East Wing	2nd Floor Boys Locker	4525691	3/28/2018	Detector Kit	0.2
Harbor Lights Middle School	East Wing	Basement Office	4525998	3/28/2018	Detector Kit	0.2
Harbor Lights Middle School	East Wing	Basement Office	4525665	3/28/2018	Detector Kit	0.2
Harbor Lights Middle School	East Wing	2nd Floor Gym - 13	4607995	3/28/2018	Detector Kit	0.2
Harbor Lights Middle School	Main Building	2nd Floor Office	4525728	3/28/2018	Detector Kit	1.5
Harbor Lights Middle School	Main Building	2nd Floor Library	4607929	3/28/2018	Detector Kit	1.3
Harbor Lights Middle School	Main Building	2nd Floor Office	4607990	3/28/2018	Detector Kit	0.2
Harbor Lights Middle School	Main Building	2nd Floor Office	4525929	3/28/2018	Detector Kit	0.2
Harbor Lights Middle School	East Wing	2nd Floor Gym	4453115	3/28/2018	Detector Kit	0.7
Harbor Lights Middle School	East Wing	2nd Floor Gym	4525778	3/28/2018	Detector Kit	0.7
Harbor Lights Middle School	East Wing	2nd Floor Gym	4453073	3/28/2018	Detector Kit	0.3
Harbor Lights Middle School	East Wing	2nd Floor Gym	4525952	3/28/2018	Detector Kit	1.0
Harbor Lights Middle School	East Wing	2nd Floor Gym	4453247	3/28/2018	Detector Kit	0.4
Harbor Lights Middle School	East Wing	2nd Floor Gym	4453324	3/28/2018	Detector Kit	0.4
Harbor Lights Middle School	East Wing	2nd Floor Gym	4453240	3/28/2018	Detector Kit	0.6
Harbor Lights Middle School	East Wing	2nd Floor Gym	4525891	3/28/2018	Detector Kit	0.4
Harbor Lights Middle School	East Wing	2nd Floor Gym	4533396	3/28/2018	Detector Kit	0.4
Harbor Lights Middle School	East Wing	2nd Floor Gym	4525682	3/28/2018	Detector Kit	0.2
Harbor Lights Middle School	East Wing	2nd Floor Gym	4525737	3/28/2018	Detector Kit	0.3
Harbor Lights Middle School	East Wing	2nd Floor Gym - 14	4337176	3/28/2018	Detector Kit	1.2
Harbor Lights Middle School	Main Building	2nd Floor Office	4607940	3/28/2018	Detector Kit	0.2