## Water Testing Results - Harbor Lights Middle School Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
7/8 Hall Bathroom Girls' Faucet	19690216-022BF	11/4/2022	2
6th Grade Room 2 Classroom Faucet	19690216-030CF	11/4/2022	ND
Any first we testing at an above the estion level of 45 mmb is immediately noncored from somice			
Any fixture testing at or above the action level of 15 ppb is immediately removed from service			
and cannot be returned to service until it has be	en remediated and p	passed follow-up to	esting
RETESTS			
ND = Non Detect - Lead level is below the set detection limits of 1 ppb			