

# Radon Testing Results - Ocean Crest Elementary School

## Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date sampled	Type of test	Results (pCi/L)
Ocean Crest Elementary School	Main Building	2nd Floor Office	4525685	3/28/2018	Detector Kit	0.3
Ocean Crest Elementary School	Main Building	Basement Office	4525667	3/28/2018	Detector Kit	0.3
Ocean Crest Elementary School	Main Building	Basement Office	4525888	3/28/2018	Detector Kit	0.2
Ocean Crest Elementary School	Main Building	Basement Office	4525671	3/28/2018	Detector Kit	0.3
Ocean Crest Elementary School	Main Building	2nd Floor Gym	4607938	3/28/2018	Detector Kit	0.2
Ocean Crest Elementary School	Main Building	2nd Floor Gym	4525794	3/28/2018	Detector Kit	0.2
Ocean Crest Elementary School	Main Building	2nd Floor Gym	4525976	3/28/2018	Detector Kit	0.2
Ocean Crest Elementary School	Main Building	2nd Floor Gym	4568722	3/28/2018	Detector Kit	0.2
Ocean Crest Elementary School	Main Building	2nd Floor Staff Room	4337179	3/28/2018	Detector Kit	0.2
Ocean Crest Elementary School	Main Building	2nd Floor Counselor	4525989	3/28/2018	Detector Kit	0.3
Ocean Crest Elementary School	Main Building	Basement Gym	4453274	3/28/2018	Detector Kit	0.4
Ocean Crest Elementary School	Main Building	2nd Floor Office Front	4525730	3/28/2018	Detector Kit	0.4