

Water Testing Results - Ocean Crest Elementary

Action Level is 15 parts per billion (ppb)

| Fixture Location/Description | Fixture ID # | Test Date | Test Result |
|------------------------------|----------------|-----------|-------------|
| SE Classroom Faucet Room 3 | 19690217-081CF | 11/4/2022 | ND |
| SE Classroom Faucet Room 4 | 19690217-082CF | 11/4/2022 | ND |
| SE Hallway Drinking Fountain | 19690217-083DW | 11/4/2022 | ND |
| NW Gym Boys Sink Faucet | 19690217-087BF | 11/4/2022 | 4 |
| West Central Faucet Room 6 | 19690217-093CF | 11/4/2022 | ND |
| North Hall Drinking Fountain | 19690217-102DW | 11/4/2022 | ND |
| NW Classroom Faucet Room 13 | 19690217-103CF | 11/4/2022 | ND |
| NW Bathroom Faucet Room 12 | 19690217-105BF | 11/4/2022 | ND |
| NW Bathroom Faucet | 19690217-107BF | 11/4/2022 | ND |
| NW Bathroom Faucet | 19690217-108BF | 11/4/2022 | ND |
| NW Classroom Faucet Room 18 | 19690217-109CF | 11/4/2022 | ND |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

| | | | |
|---------|--|--|--|
| RETESTS | | | |
| | | | |
| | | | |

ND = Non Detect - Lead level is below the set detection limits of **1** ppb